

Certificate of thermal simulation

PRODUCT

Origin Window

SIM - SOFTWARE

Win Iso 2D Pro

GLASS CENTRE
PANE U/VALUE

0.5 W/m²K (44mm triple glazing)

INSULATION

AEROGEL

Thermal Transmittance:

0.9 W/(m²K)

TESTED BY

David Ginger (Product Proving Manager)

SIGNED



Date: 05/11/2015

origin

DOORS AND WINDOWS

All simulations strictly in accordance with the requirements of ISO 10077-2:2015

Email: info@origin-global.com | Web: www.origin-global.com

Origin Frames Ltd, Sands 10 Industrial Estate, Hillbottom Road, High Wycombe, HP12 4HS

OFDL_3.96.1